

RESEARCH ARTICLE

Cross-entropy method for distribution power systems reconfiguration

Karim Sebaa¹  | Ayetül Gelen² | Hassan Nouri³

¹Laboratory of Advanced Electronic Systems (LSEA), University of Medea, Medea, Algeria

²Department of Electrical Electronic Engineering, Bursa Technical University, Bursa, Turkey

³Power Systems and Energy Research Laboratory, University of the West of England, Bristol, UK

Correspondence

Karim Sebaa, Laboratory of Advanced Electronic Systems (LSEA), University of Medea, Nouveau Pole Urbain, 26000 Medea, Algeria.
Email: sebaa.karim@univ-medea.dz

Cross-entropy (CE) is a powerful simulation method for the solution of continuous and combinatory optimization problems. The work presented here utilizes the CE method for the optimal topology of distribution power systems (DPSs). The optimal network switches are determined for the reduction of active power loss. The adapted CE method is tested on three case studies, namely, the 33-node, 83-node, and 880-node DPSs. The results are compared with other reconfiguration algorithms to demonstrate the superiority of the proposed algorithm. The impact of the distributed generation is also investigated. The effective integration of the photovoltaic panels at midday, when their production is highest and meets the peak demand, is showed. Finally, the real-time reconfiguration strategy based on the switching effort reduction is proposed and enhanced via an adequate selection of the initial switch states.

KEYWORDS

combinatory optimization, cross-entropy, distribution power system, loss reduction, reconfiguration, topology

1 | INTRODUCTION

Distribution power systems (DPSs) have gained increased importance in recent times due to the huge penetration of green energies. Because these renewable sources are characterized by their intermittent and stochastic behavior, the operating points of DPS change continuously, and to meet the optimal operation, the topology needs to follow these changes. Network reconfiguration achieved by changing the states of some maneuverable switches is widely in use by electrical engineers. It would be more practical in real time to manipulate the candidates' switches than to opt for other costly choices.^{1,2} In some segments of the DPS, switches either are open or closed.³ This option in the radial networks is used for minimization of losses as well as voltage deviations.⁴

The mathematical representation of the aforementioned option includes binary variables with a nonlinear objective function and constraint. The integer nonlinear programming (INLP) methods are well suited for such cases as these tools can deal with large-scale problems. However, they must not have exponential complexity.

Usually, four families of methods are used for reconfiguration of DPS. The first concerns the method designed for a particular objective function structure, for example, integer programming, the cutting plane,⁵ or branch-and-bound.⁶ The second contains metaheuristic methods, which have the ability to decrease the search space and do not need derivation of the objective function. In addition, these approaches are more appropriate for INLP problems and assure the exploration of the search space. Furthermore, they have the ability to avoid the convergence to local optima of the feasible region and go to a global solution, but they are very time consuming and their solutions are not stable. In recent years, the DPS reconfiguration is also achieved through metaheuristics based tools such as genetic algorithms,⁷⁻¹² simulated annealing,¹³⁻¹⁵ artificial ant colony,^{16,17} tabu search,¹⁸ particle swarm optimization,¹⁹ hybrid differential evolution

This is an open access article under the terms of the Creative Commons Attribution License, which permits use, distribution and reproduction in any medium, provided the original work is properly cited.

© 2019 The Authors. *Engineering Reports* Published by John Wiley & Sons Ltd.




FIGURE 1 The topology of a distribution power system

(HDE),²⁰ and the artificial immune systems.^{21,22} The drawback of these approaches is that they are time consuming and their operation depends on careful selection of parameters. The third family is concerned with the heuristic based search family such as the method proposed by Baran and Wu²³ and the minimum cost maximum flow (MCMF) proposed by Ababei and Kavasseri.²⁴ These methods provide a fast, robust, and stable solution but do not guarantee the global optima.

The last family contains the determinist approach, which is the recent trend. For example, Taylor and Hover²⁵ have introduced three new formulations of the reconfiguration problem: the quadratic programming (QP), the quadratic constrained programming (QCP), and the second-order cone programming (SOCP). Recently, Jabr et al²⁶ have proposed the mixed integer convex programming (MICP) formulation and Ahmadi and Marti²⁷ proposed the linearized power flow with the mixed-integer quadratic constrained programming (MIQCP). Although these methods are very fast, they cannot always guarantee global optimum and are computationally time consuming. Most recently, Rubinstein²⁸ proposed the cross-entropy (CE) method for solving a rare-event (RE) simulation problem, and thereafter, this method is extended for the solution of optimization problems.²⁹ It is reported by Sebaa et al³⁰ and Ernst et al³¹ that, in several applications, the CE method for engineering optimization problems achieves better results than other metaheuristic methods.

The CE method belongs to Monte Carlo (MC) methods. It uses the importance sampling technique (IS) in which this propriety facilitates its ability to deal with large-scale problems with poor simulation resources. MC methods are suitable for problems when other techniques are too difficult to solve or poses a heavy burden computationally. Another motivation behind the choice of the CE method is that it converges to the global optima when there are many local optima.

This paper introduces the CE method to the problem of reconfiguration of the distribution networks and is organized as follow. Section 2 describes the problem statement, and Section 3 focuses on the presentation of the CE approach, especially when discrete variables are involved in the optimization problem. Finally, Section 4 presents case studies where the three known distribution networks are tested.

2 | LOSS REDUCTION

It is beneficial to recall some concepts of the graph theory field before proceeding to the concept of DPS reconfiguration. The topology of DPS depends on the arrangement of its elements. In a graphic frame, this topology is determined by a finite set $Y = \{y_1, y_2, y_3, \dots, y_N\}$ of vertices or buses and a finite set $B = \{b_1, b_2, b_3, \dots, b_M\}$ of links or branches.

The Y and B sets correspond to the definition of a graph that is denoted as $G(Y, B)$.²⁴ The orientation of each branch can be a priori or indefinite as shown in Figure 1.

The reconfiguration problem can be seen as the selection of the branch x_i from the branches $\Omega_i = \{ind_{1,i}, ind_{2,i}, \dots, ind_{m_i,i}\}$ in fundamental path i containing m_i branches that should be switched off. Initially, the fundamentals paths have to be evaluated.

These paths are chosen in such a way that, when the initially switched-off branch is switched on with any branch of the same path that is initially switched off, the network keeps its connectivity and the maneuver does not affect any other path. This paper assumes that the set Ω_i is a priori that is known.

Noting that $ind_{1,i}$ is originally the switched-off branch, then the state space is $\Omega = \Omega_1 \times \Omega_2 \cdot \dots \times \Omega_{NI}$ and the candidate solutions have the form $X = (x_1, x_2, \dots, x_{NI})$.

2.1 | Performance function

Losses cannot be avoided and are one of the technical and economic problems, which are presented by the Joule's formula

$$\min G(X) = \min \sum_{k \in X} R_k \cdot I_k^2, \quad (1)$$

where R_k and I_k are the resistance and the current of the branch k , respectively.

Defining the network constraints as follows:

- (i) Kirchhoff equations;
- (ii) voltage limits $U_i^{\min} \leq U_i \leq U_i^{\max}$ ($i = \overline{1, N}$);
- (iii) current limits $I_k \leq I_k^{\max}$ ($k = \overline{1, M}$);
- (iv) connectivity and radiality.

In this paper, the back forward sweep technique that includes two steps is used to ensure that constraints (i) and (ii) are satisfied by the load flow (LF) routine. A faster LF routine is achieved with the branch exchange approach. For such an approach, first, the LF needs to be performed on the original network represented by the vector $X_{orig} = (ind_{1,1}, ind_{1,2}, \dots, ind_{1,Nl})$. For example, the LF for the vector $X = (ind_{k1,1}, ind_{k2,2}, \dots, ind_{kNl, Nl})$ is carried out by exchanging the branches $(ind_{k1,1}$ and $ind_{1,1})$, $(ind_{k2,2}$ and $ind_{1,2})$, and so on. Furthermore, the constant load model is adopted throughout this work and as Equation (1) is composed of discrete variables, a discrete optimization solution, such as the CE method is utilized.

3 | CE METHOD FOR DISCRETE OPTIMIZATION

Originally, the CE method is developed to estimate occurrence of an RE in stochastic networks, and then, its suitability is confirmed for several optimization problems. A sequence of probability density functions (pdf) that estimate this RE problem are generated until they converge to a degenerated pdf and the global optimum is reached.

Two steps could summarize the CE method.

- Generation of random variables, vectors, or paths according to specific probability density functions (pdfs).
- Updating the pdfs based on the previous step best samples.

3.1 | CE for optimization

Let $G(\cdot)$ be the objective function to be minimized in the domain Ω . Suppose that the task is to find out the global minimum of $G(\cdot)$ over Ω and the global optima is X^* and $G(X^*) \leq \delta^*$

$$G(X^*) = \delta^* = \min_{X \in \Omega} G(X). \quad (2)$$

As the CE method for optimization is an extension of the CE method for RE estimation, the event associated with (1) is the probability that is represented by $\{G(X) \leq \delta\}$. Considering that X belongs to some pdf $f(x, u)$ on Ω domain, hence X depends on u and the level δ . Thereby, the randomness aspect is introduced to the original problem to provide a stochastic model. When δ is close to δ^* , the probability $\lambda = \Pr(G(X) \leq \delta)$ become very small and it is considered as an RE probability. The IS technique is one of the methods that could estimate this probability

$$\hat{\lambda} = \frac{1}{L} \sum_{k=1}^L \frac{f(X_k)}{g(X_k)} I_{\{G(X_k) \leq \delta\}}, \quad (3)$$

where X_k is an independent and identically distributed (iid) samples generated from a known pdf g . The pdf that gets a zero variance estimator is $g^*(x) = f(x) I_{\{G(x) \leq \delta\}} / \lambda$. However, it depends on the unknown probability λ . The role of the CE method is to determine an IS pdf $f(\cdot, v)$ that is close to g^* in terms of the CE distance (or Kullback-Leibler distance)

$$D(g^*, f(\cdot, v)) = E_{g^*} \left(\ln \frac{g^*(X, v)}{f(X, v)} \right) \quad (4)$$

The parameter v should maximize the following expectation (u is the parameter of the previous pdf):

$$E_{f(X,u)} (I \{G(X) \leq \delta\} \ln f(X, v)). \quad (5)$$

One more time, using other IS with pdf $f(\cdot, w)$, the next expectation should be maximized based on v

$$E_{f(X,w)} (I \{G(X) \leq \delta\} W(X, u, w) \ln f(X, v)),$$

where $W(X, u, w) = f(X, u)/f(X, w)$ is the likelihood ratio between the two pdfs. The parameter v can be computed based on the called stochastic counterpart (SC) problem.

$$\frac{1}{N} \sum_{k=1}^N I \{G(X_k) \leq \delta\} W(X_k, u, w) \ln f(X_k, v) \quad (6)$$

Here, X_k are iid samples generated from $f(\cdot, w)$. It is easy to solve the SC problem if the pdf $f(\cdot, v)$ belongs to a special distribution family like exponential, normal, or Bernoulli laws. This will be done by the computation of gradient with respect to v of

$$\sum_{k=1}^N I \{G(X_k) \leq \delta\} W(X_k, u, w) \nabla (\ln f(X_k, v)) = 0. \quad (7)$$

The typical CE algorithm for optimization is as follows.

1. Give the input data
 - a. the initial parameter vector v_0 , the pdf family $f(\cdot, v)$, and the domain Ω
 - b. the sample size L and the quantile ratio ε and the degeneration error σ

Set $t:=1$ the iteration counter and

2. $elite = \varepsilon L$
3. While the $\|v_t - v_{t-1}\| \geq \sigma$
 - i. Generate iid random vectors X_k ($k = 1:L$) belonging to $f(\cdot, v_{t-1})$
 - ii. Compute the objective functions $G(X_k)$ and sort them in increasing order
 - iii. Set $\delta_t := G(X_{elite})$
 - iv. Solve the SC problem and get v_t

$$\sum_{k=1}^N I \{G(X_k) \leq \delta\} W(X_k, v_0, v_{t-1}) \text{Grad} (\ln f(X_k, v_t)) = 0$$
 Set $t:=t+1$
4. End of the while loop

3.2 | CE for the reconfiguration problem

The reconfiguration of DPS for loss reduction is a discrete optimization problem,²⁹ where the state space is $\Omega = \{ind_{1,1}, ind_{2,1}, \dots, ind_{m_1,1}\} \times \{ind_{1,2}, ind_{2,2}, \dots, ind_{m_2,2}\} \times \dots \times \{ind_{1,Nl}, ind_{2,Nl}, \dots, ind_{m_{Nl},Nl}\}$. If X_1, X_2, \dots, X_L are iid random vectors taking values in Ω domain with probabilities $P = (p_{1,1}, p_{2,1}, \dots, p_{m_1,1}) \times (p_{1,2}, p_{2,2}, \dots, p_{m_2,2}) \times \dots \times (p_{1,Nl}, p_{2,Nl}, \dots, p_{m_{Nl},Nl})$ (note that). The pdf chosen for the random variable $X = (x_1, x_2, \dots, x_{Nl})$ is

$$f(X, P) = \prod_{k=1}^{m_1} P_{k,1}^{I_{\{x_1=ind_{k,1}\}}} \times \prod_{k=1}^{m_2} P_{k,2}^{I_{\{x_2=ind_{k,2}\}}} \times \dots \times \prod_{k=1}^{m_{Nl}} P_{k,Nl}^{I_{\{x_{Nl}=ind_{k,Nl}\}}}. \quad (8)$$

After solution of the SC problem (7), it is easy to prove that

$$\frac{d \ln f(X, P)}{d p^{k,j}} = \frac{I_{\{x_j=ind_{k,j}\}}}{p^{k,j}} - \frac{I_{\{x_j=ind_{m_j,j}\}}}{p_{m_j,j}} \quad \left(k = \overline{1, m_j - 1} \quad \text{and} \quad j = \overline{1, Nl} \right).$$

Considering $\sum_{k=1}^{m_j} p_{k,j} = 1$. The updated probabilities are

$$P_{k,j}^{t+1} = \frac{\sum_{i=1}^L I_{\{G(X_i) \leq \delta\}} W_i(X_i, P^0, P^t) I_{\{x_{ij} = \text{ind}_{k,j}\}}}{\sum_{i=1}^L I_{\{G(X_i) \leq \delta\}} W_i(X_i, P^0, P^t)}, \quad (9)$$

where P^0 and P^t are the vectors of initial and previous probabilities. As this optimization involves discrete random variables, the likelihood ratio is set to $W = 1$. Therefore, (9) becomes

$$P_{k,j}^t = \sum_{X_i \in \text{Elite}} I_{\{x_{ij} = \text{ind}_{k,j}\}} / N_{\text{Elite}}, \quad (10)$$

where the *Elite* is the set of the variables X_k that verifies $G(X_k) \leq \delta$ and $N_{\text{Elite}} = \#\text{Elite}$. The CE algorithm for the reconfiguration of DPS is as follows.

1. Give the input data

- a. The set of branches B
- b. The indices of fundamental loops indices Ω_i

c. The initial parameter vector $P_0 = \left(\underbrace{\frac{1}{m_1}, \dots, \frac{1}{m_1}}_{m1 \text{ times}}, \underbrace{\frac{1}{m_2}, \dots, \frac{1}{m_2}}_{m2 \text{ times}}, \dots, \underbrace{\frac{1}{m_{NL}}, \dots, \frac{1}{m_{NL}}}_{mNL \text{ times}} \right)$

- d. The pdf family $f(\cdot, P^t)$ (8)
- e. The objective function for the original configuration $G(X_{\text{orig}})$
- f. The sample size L , the quantile ratio ε and the degeneration error σ

2. Set $t:=1$ the iteration counter and $N_{\text{Elite}} = \varepsilon L$

3. While the $\|P^t - P^{t-1}\| \geq \sigma$

- i. Generate idd random vectors X_k ($k = 1:L$) belonging to $f(\cdot, v_{t-1})$
- ii. Compute the objective functions $G(X_k)$ and sort them in increasing order
- iii. Set $\delta_t := G(X_{N_{\text{Elite}}})$
- iv. Update the probabilities $p_{k,j}^{t+1} = \sum_{X_i \in \text{Elite}} I_{\{x_{ij} = \text{ind}_{k,j}\}} / N_{\text{Elite}}$
- v. Set $t:=t+1$

4. End of the while loop

At each iteration, the probability $p_{k,j}^{t+1}$ will be updated. At the iteration t , the solutions are sorted according to their objective function, then only the best N_{Elite} samples are kept. The probability $p_{k,j}^{t+1}$ is simply the occurrence of the branches $\text{ind}_{k,j}$ in the loop j and of course among elements of *Elite*.

4 | CASE STUDIES

4.1 | 33-node DPS

This test case shown in Figure 2 is known as Baran and Wu's network.²³ Its nominal voltage is 12.66 kV. There are 32 nodes and 1 feeder. Originally, lines 1-32 are switched on and lines 33-37 are switched off.

There are five fundamental loops in Figure 2. These are $\Omega_1 = \{36, 32, 31, 30, 29, 15, 16, 17\}$; $\Omega_2 = \{37, 28, 24, 23, 22, 3, 4, 5, 25, 26, 27\}$; $\Omega_3 = \{33, 7, 6, 2, 18, 19, 20\}$; $\Omega_4 = \{35, 8, 11, 10, 9, 21\}$; and $\Omega_5 = \{34, 14, 12, 13\}$.

The original or the total circuit loss is 202.69 kW. For the application of the CE method, the program is written and run with MATLAB[®] that operates under Core i5, 2.5 GHz and 8 Gb RAM.

Usually, the quantile ratio is selected between 0.01 and 0.1. It has been suggested that the size of elite set should be sufficiently large to provide a good estimation of pdfs (9). In this paper, $\varepsilon = 0.1$ and $L = 50$ are selected for the desired




FIGURE 2 A 33-node distribution power system with five fundamental loops (in color)




FIGURE 3 Evolution of the probabilities using the proposed cross-entropy method

estimation of pdfs. The initial probabilities are $P_0 = \left(\underbrace{\frac{1}{8}, \dots, \frac{1}{8}}_{8 \text{ times}}, \underbrace{\frac{1}{11}, \dots, \frac{1}{11}}_{11 \text{ times}}, \dots, \frac{1}{4}, \frac{1}{4}, \frac{1}{4}, \frac{1}{4} \right)$. From Figure 3, the CE method

converges to the global solution within 3 iterations, the optimal solution is to switch off the lines {32, 37, 7, 9, 14}, which leads to the reduction of network losses to 139.55 kW.

For the purpose of comparison, Table 1 presents the results obtained by approaches proposed in literature and the CE method. It shows the optimal configuration, the power loss, and the convergence time for the Baran's network. The convergence time is achieved with 5 iterations, which can be multiplied by 3/5 as the optimal performance is reached by 3 iterations. This, in turn, reduces the proposed method's convergence time to 1.1713 seconds. All the presented approaches

Methods: In the literature and the proposed (CE)	Switched-off lines	Power loss (kW)	Time (s)	Platform
Base	33 34 35 36 37	202.686		
Proposed ^a	7 9 14 32 37	139.554	1.1713	MATLAB
Baran and Wu's method ²³	7 11 34 36 37	144.540	0.0004	C++
MCMF ²⁴	7 11 34 36 37	144.540	0.0004	C++
GA ³²	7 9 14 32 37	139.554	7.2000	MATLAB
QP ²⁵	7 9 14 32 37	139.554	0.2100	AMPL/
QCP ²⁵	7 9 14 32 37	139.554	1.4300	CPLEX
SOCP ²⁵	7 9 14 32 37	139.554	12.8000	
MILP ^{b33}	7 9 14 32 37	139.554	0.1500	CPLEX

^aThis result is the best one selected from 10 runs.

^bMixed integer linear programming (MILP).

Abbreviations: CE, cross-entropy; DPS, distribution power system; GA, genetic algorithm; MCMF, minimum cost maximum flow; QCP, quadratic constrained programming; QP, quadratic programming; SOCP, second-order cone programming.




FIGURE 4 A 94-node distribution power system with 13 fundamental loops (initially, lines 63-74, 23-86, 24-28, ..., in color are switched off)

have met the optimal configuration, except the heuristics approaches of Baran and Wu²³ and Ababei and Kavasseri²⁴ that differ from the global optima by 3.57%, but their convergence time is short.

4.2 | 94-node DPS

It is also known as the Taiwan DPS and has been introduced in the work of Su et al.³⁴ It contains 94 nodes, 11 feeders, 83 normally closed switches, and 13 open lines. Therefore, the number of fundamental loops is 13. Its nominal voltage is 11.4 kV as depicted in Figure 4.

The quantile ratio and the sample size are 0.1 and 180, respectively. The CE approach converges within 13.476 seconds to the global solution, which is clearly fast than the convergence time of other methods. However, the Baran and Wu's method is the fastest and achieves the global optima. Results obtained by approaches proposed in literature and the CE methods are shown in Table 2.

4.3 | 880-node DPS

This test case is created using data from 135-node DPS and data from 201-node DPS. It contains 880 nodes, 7 feeders, 873 normally switched-off lines, and 27 tie lines.²⁴ Figure 5 shows the simplified representation of this system.

Methods: In the literature and the proposed (CE)	Switched-off lines	Power loss (kW)	Time (s)	Platform
Base	874 875 876 877 878 879 880 881 882 883 884 885 886 887 888 889 890 891 892 893 894 895 896 897 898 899 900	1496.402		
Proposed^a	084 130 141 159 190 282 288 306 312 409 411 452 494 596 616 630 631 637 698 815 844 885 888 889 890 896 900	457.027	214.269	MATLAB
Baran and Wu's method ²³	084 132 140 159 190 244 282 285 311 410 413 419 451 494 616 630 631 638 698 815 844 882 885 888 890 893 900	462.484	0.043	C++
MCMF ²⁴	084 136 143 156 190 242 282 285 289 410 411 452 494 574 596 616 630 631 636 815 844 882 885 888 889 894 900	463.097	0.017	C++
QP ²⁵	n/a	457.04	37370	AMPL/CPLEX
MILP ³⁵	084 131 140 159 190 244 282 288 306 312 409 411 452 494 596 616 629 631 637 698 815 844 885 888 889 890 900	457.916	398	CPLEX

^aThis result is the best one selected from 10 runs.

Abbreviations: ACSA, ant colony search algorithm; CE, cross-entropy; DPS, distribution power system; MCMF, minimum cost maximum flow; MILP, mixed integer linear programming; QP, quadratic programming.

TABLE 3 Comparison study for the 880-node DPS (CE for $L = 600$, $\epsilon = 0.1$)



algorithm has run 100 times. The probability to reach the global optima G^* is equal to $\sum_{i=1}^{100} I\{G_i - G^*\}/100$, where G_i is the solution found at the i th run and the suboptimality of the problem is $\sum_{i=1}^{100} [(G_i - G^*)/G^*]/100$.

Over 100 runs, the proposed method has not been able to meet the global optima twice for the Baran and Taiwan test cases and once for the Ababei test case. The CE algorithm converges every time to the degenerated pdfs within a few iterations. Moreover, the convergence time increases quadratically with the problem size as depicted in Figure 6. However, as the sample size increases linearly with the problem size, the complexity of the algorithm is defined by $O(n^2)$.

The outcome of the proposed approach is similar to that of those presented in the reference papers (shown in Tables 1 to 4). In addition, the proposed method does not require enormous simulation materials, as by its nature, the CE approach uses the elitism concept and at each step the new pdf is adjusted by the previous elite set. Hence, the reconfiguration, based on the CE method, is relatively quicker than other methods (the reference papers).

TABLE 4 Impact of the problem's size on the cross-entropy convergence

Case/nodes	$L = \#P$ $\times 5$	Average number of iteration to converge	Suboptimality of the problem	Probability to meet the global optima	Average time to degenerate
Baran and Wu's DPS/33	36×5	5.40	$5.9358e-05$	0.98	7.0276
Taiwan's DPS/94	78×5	8.12	$6.9438e-06$	0.98	29.1979
Ababei and Kavasseri's DPS/880	457×5	14.60	$1.2953e-06$	0.99	816.0101

**FIGURE 6** Convergence time of the cross-entropy method**FIGURE 7** Active power losses versus maximum number of maneuvers

4.5 | Limits on the maneuvers number

In order to include limits in the maximum number of switches, the following constraint is considered:

$$H(X) = n_{sw} - n_{max} = \left(\sum_{i=1}^{NI} I(x_i \neq ind_{1,i}) \right) - n_{max} \leq 0, \quad (11)$$

where n_{max} , n_{sw} , and x_i are the maximum number of switches permitted, the current number of switches, and the index of the switch in the line of loop i , respectively.

This constraint is considered when generating samples by the acceptance-rejection method or the Gibbs sampling via the truncation of the samples do not follow Equation (11). However, the easy way to handle this constraint is to use the penalty function d . The new performance function becomes

$$G(X) = G(X) + d \times \max(0, H(X)), \quad (12)$$

where the penalty function is

$$d = \frac{P_{loss}^{orig}}{NI}, \quad (13)$$

and P_{loss}^{orig} is the total active power loss of the original configuration (network before reconfiguration process). Figure 7 shows the influence of the maximum number of switches on the total power loss of the 94-node DPS. This DPS contains 13 possible switches. Hence, the number of n_{max} takes values from 0, 1, up to 13. For $n_{max} \geq 9$, the total active loss is constant because the optimal solution corresponds to the switches of only nine lines. A good performance can be achieved by the switches of only five lines, which corresponds to the reduction of 11.53% of the total power loss. Note that the optimal solution achieves a reduction of 11.68%.




FIGURE 8 Daily photovoltaic panel's output power (— Gen 1, 3, 4, 5, 6, 8, 9, 10, and 11; - - - Gen 2 and 7)




FIGURE 9 Daily load profile

4.6 | Distributed generators

In this section, a 94-node network is considered to study the impact of the photovoltaic panels (PV) that are installed at the generation node, on the network global loss. These PVs are assumed to have the same capacity as the traditional generators connected to the same node. Figure 8 shows the profile of PVs power.

Furthermore, the loads are varying in time and are supposed to have a household's profile. Other profiles such as the industrial profile or a mixture of these two profiles could also be investigated. Only the load profile at the 15th node is presented in Figure 9.

The objective function must include various criterions of the classical objectives such as voltage deviation improvement, load balancing, and the global active loss. In addition, attempts should be made to reduce the number of switching maneuvers during the day. To satisfy all of the above objectives, a compound of these criterions would guarantee the aim

$$\min \left\langle \frac{P_{loss}}{P_{loss}^{orig}} + \frac{1}{N} \sum_{i=1}^N \frac{U_n - U_i}{U_n} + \frac{1}{M} \sum_{k=1}^M \frac{|I_k|}{I_k^{max}} + \sum_{j=1, P_{G_j} - P_{PV_j} > 0}^{Nsub} (P_{G_j} - P_{PV_j}) + \sum_{m=1}^{NI} I(x_m^{new} \neq x_m^{old}) \right\rangle, \quad (14)$$

where x_m and x_m^{old} respectively are the current and the previous indices of the switched-off branch in the loop m (I), which is known as the indicator function.

The optimization problem described by (14) should be repeated every 15 minutes (96 samples every 24 hours). Based on how the initial states of switches are selected, two cases could be analyzed. The first case considers the optimal configuration of the network as discussed earlier and the second case considers the original configuration of the network. From the results presented in Figures 10 to 12, one can clearly observe that the first choice leads to a minimum number of maneuvering of switches in 1 day, whereas the second case shows the importance of switching. Furthermore, Figure 13 shows that the voltage drop for both cases is low (around 5%) and similarity exists between their voltage profiles. In addition, Figures 14 and 15 depict similarity in power loss and current balancing profiles.




FIGURE 10 Evolution of branches' state—loops #3, 4, 5, 12, and 13 do not change their state (initialized by the optimal configuration for 94-node network)




FIGURE 11 Evolution of branches' state—loops #4, 5, 6, and 13 do not change their state (initialized by the original configuration for 94-node network)




FIGURE 12 The number of switches that change state in 1 day for 94-node network

Figure 16 confirms that the supplied non-green power reaches its minimum value at midday, ie, when the PV production is the highest. Moreover, the blue curves in Figures 13 to 16 represent the scenario without the green sources. These Figures show that, at midday, the impact of the PVs is important. However, the losses are slightly lower because, in the case “with DG,” the importance is given to the consumption of green energy than to the loss minimization.

The same analysis is conducted for an 880-node power system assuming that this network is subject to the same amount of PVs penetration at nodes 1, 3, 4, 5 with a maximum power of 44.32 MW at 14 hours (02:00 pm). The results are presented in Figures 17 to 23 and confirm the advantage of the green energy.




FIGURE 13 Voltage drop variation in 1 day for 94-node network (w DG = with DG). DG, distributed generation




FIGURE 14 Network global loss in 1 day for 94-node network (w/o DG = without DG). DG, distributed generation




FIGURE 15 Current balancing over 1 day for 94-node network




FIGURE 16 The supplied non-green power over 1 day for 94-node network

FIGURE 17 Evolution of branches' state (initialized by the optimal configuration for 880-node network)




FIGURE 18 Evolution of branches' state (initialized by the original configuration for 880-node network)




FIGURE 19 The number of switches that change state in 1 day for 880-node network





FIGURE 20 Voltage drop variation in 1 day for 880-node network






FIGURE 21 Network global loss in 1 day for 880-node network




FIGURE 22 Current balancing over 1 day for 880-node network




FIGURE 23 The supplied non-green power over 1 day for 880-node network

The average number of switches (the maximum number of switches is 457) that change state or initialize is 11.20. However, in general, the average number of switches without the initialization is 11.51.

5 | CONCLUSION

The proposed CE algorithm is successfully applied to the problem of reconfiguration in DPSs. The results demonstrated that the optimal state of line switches can be obtained within a few iterations with reasonable convergence time and the computational complexity of this algorithm displays quadratic $O(n^2)$ characteristics.

Furthermore, based on analysis of the results, the superiority of the proposed method is confirmed over its counterpart heuristic and metaheuristic algorithms. It can even compete with direct mathematical methods, such as QP and MILP. These findings are further reinforced when the proposed algorithm is applied to a DPS containing many distributed generators, such as PVs that provide power over a half day (daylight) or shorter period, and in addition, when the load and the generation are varied.

CONFLICT OF INTEREST

The authors declare that there is no conflict of interest regarding the publication of this article.

NOMENCLATURE

Y	A finite set of N buses or nodes
B	A finite set of M branches
$G(Y, B)$	Axiomatic representation of a graph
Nl	Number of the fundamental paths
Ω_i	The set of the branch indices belonging to the i th path
m_i	The number of branches in the i th path
$ind_{j,i}$	The j th branch belonging to the i th path
Ω	The state space
$X = (x_1, x_2, \dots, x_{Nl}) \in \Omega$	The candidate solution
$G(X)$	A performance/objective function
R_k and I_k	Resistance and the current of the branch k
X^*	The global optima
δ^*	The minimum of $G(\cdot)$
$f(\cdot, u), g(\cdot, v)$	pdfs with a parameters u or v following a special family of pdf
$I_{\{\cdot\}}$	The indicator function is equal to 1 if the logic expression $\{\cdot\}$ is true otherwise it is 0
$D(\cdot, \cdot)$	The Kullback-Leibler (cross-entropy) distance
$E_f(\cdot)$	The expectation of the function $f(\cdot)$
$W(\cdot, u, w)$	Likelihood ratio between the two pdfs $f(\cdot, u)$ and $f(\cdot, w)$
L	The sample size
ε	The quantile ratio
σ	Degeneration error
N_{Elite}	The size of the elite set <i>Elite</i>
t	The iteration counter
$p_{k,j}^t$	the probability of the occurrence of the $ind_{k,j}$ at the iteration t

ORCID

Karim Sebaa  <https://orcid.org/0000-0002-8896-2823>

REFERENCES

1. Badrana O, Mekhilef S, Mokhlis H, Dahalan W. Optimal reconfiguration of distribution system connected with distributed generations: a review of different methodologies. *Renew Sustain Energy Rev.* 2017;73:854-867.
2. Bernardon DP, Mello APC, Pfitscher LL, Canha LN, Abaide AR, Ferreira AAB. Real-time reconfiguration of distribution network with distributed generation. *Electr Pow Syst Res.* 2014;107:59-67.
3. Sarfi RJ, Salama MMA, Chikhani AY. A survey of the state of the art in distribution system reconfiguration for system loss reduction. *Electr Pow Syst Res.* 1994;31(1):61-70.

4. Kalantar M, Dashti R, Dashti R. Combination of network reconfiguration and capacitor placement for loss reduction in distribution system with based genetic algorithm. In: Proceedings of the 41st International Universities Power Engineering Conference; 2006; Newcastle-upon-Tyne, UK.
5. Ceria S, Cordier C, Marchand H, Wolsey LA. Cutting planes for integer programs with general integer variables. *Mathematical Programming*. 1998;81(2):201-214.
6. Hindi KS, Brameller A. Design of low-voltage distribution networks: a mathematical programming method. *Proc Inst Electr Eng*. 1977;124(1):54-58.
7. Torres-Jimenez J, Guardado JL, Rivas F, Maximov S, Melgoza E. Reconfiguration of power distribution systems using genetic algorithms and spanning trees. Paper presented at: Electronics, Robotics and Automotive Mechanics Conference; 2010; Cuernavaca, Mexico.
8. Torres J, Guardado JL, Rivas-Dávalos F, Maximov S, Melgoza E. A genetic algorithm based on the edge window decoder technique to optimize distribution systems reconfiguration. *Int J Electric Power Energy*. 2013;45(1):28-34.
9. Mirhoseini S, Hosseini S, Ghanbari M, Ahmadi M. A new improved adaptive imperialist competitive algorithm to solve the reconfiguration problem distribution systems for loss reduction and voltage profile improvement. *Electric Power Energy Syst*. 2014;55(1):128-143.
10. Mazza A, Chicco G, Russo A. Optimal multi-objective distribution system reconfiguration with multi criteria decision making-based solution ranking and enhanced genetic operators. *Int J Electric Power Energy*. 2014;54(1):255-267.
11. Chiang H-D, Jean-Jumeau R. Optimal network reconfiguration in distribution system. Part 2: solution algorithms and numerical results. *IEEE Trans Delivery*. 1990;5(3):1568-1574.
12. Duan D-L, Ling X-D, Xiao-Yue W, Bin Z. Reconfiguration of distribution network for loss reduction and reliability improvement based on an enhanced genetic algorithm. *Electr Power Energy Syst*. 2015;64:88-95.
13. Zhigang M. Study on distribution network reconfiguration based on genetic simulated annealing algorithm. Paper presented at: China International Conference Electricity Distribution; 2008; Guangzhou, China.
14. Jeon Y-J, Kim J-C, Kim J-O, Shin J-R, Lee KY. An efficient simulated annealing algorithm for network reconfiguration in large-scale distribution systems. *IEEE Trans Power Deliv*. 2002;17(4):1070-1078.
15. Stojanović B, Rajić T. Novel approach to reconfiguration power loss reduction problem by simulated annealing technique. *Int Trans Electr Energy Syst*. 2017;e2464. <https://doi.org/10.1002/etep.2464>
16. Abdelaziz AY, Osama RA, El-Khodary SM. Reconfiguration of distribution systems for loss reduction using the hyper-cube ant colony optimisation algorithm. *IET Gener Transm Distribution*. 2012;6(2):176-187.
17. Chang C-F. Reconfiguration and capacitor placement for loss reduction of distribution systems by ant Colony search algorithm. *IEEE Trans Power Syst*. 2008;23(4):1747-1755.
18. Junior BRP, Cossi AM, Contreras J, Mantovani JRS. Multiobjective multistage distribution system planning using tabu search. *IET Gener Transm Distribution*. 2014;8(1):35-45.
19. Kumar D, Singh A, Mishra SK, Jha RC, Samantaray SR. A coordinated planning framework of electric power distribution system: intelligent reconfiguration. *Int Trans Electr Energy Syst*. 2018;e2543. <https://doi.org/10.1002/etep.2543>
20. Su C-T, Lee C-S. Network reconfiguration of distribution systems using improved mixed-integer hybrid differential evolution. *IEEE Trans Power Deliv*. 2003;18(3):1022-1027.
21. Alonso FR, Oliveira DQ, de Souza ACZ. Artificial immune systems optimization approach for multiobjective distribution system reconfiguration. *IEEE Trans Power Syst*. 2015;30(2):840-847.
22. Mohamed Imran MKA. A new power system reconfiguration scheme for power loss minimization and voltage profile enhancement using fireworks algorithm. *Electr Power Energy Syst*. 2014;62:312-322.
23. Baran ME, Wu FF. Network reconfiguration in distribution systems for loss reduction and load balancing. *IEEE Trans Power Deliv*. 1989;4(2):1401-1407.
24. Ababei C, Kavasseri R. Efficient network reconfiguration using minimum cost maximum flow-based branch exchanges and random walks-based loss estimations. *IEEE Trans Power Syst*. 2011;6(1):30-37.
25. Taylor JA, Hover FS. Convex models of distribution system reconfiguration. *IEEE Trans Power Syst*. 2012;27(3):1407-1412.
26. Jabr RA, Singh R, Pal BC. Minimum loss network reconfiguration using mixed-integer convex programming. *IEEE Trans Power Syst*. 2012;27(2):1106-1115.
27. Ahmadi H, Marti JR. Distribution system optimization based on a linear power-flow formulation. *IEEE Trans Power Syst*. 2015;25(1):2073-2080.
28. Rubinstein RY. Optimization of computer simulation models with rare events. *Eur J Oper Res*. 1997;99(1):89-112.
29. Kroese DP, Rubinstein RY, Glynn PW. The cross-entropy method for estimation. In: *Handbook of Statistics: Machine Learning: Theory and Applications*. Amsterdam, The Netherlands: Elsevier; 2013:19-34.
30. Sebaa K, Guéguen H, Boudour M. Mixed integer non-linear programming via the cross-entropy approach for power system stabilisers location and tuning. *IET Gener Transm Distribution*. 2010;4(8):928-939.
31. Ernst D, Glavic M, Stan G-B, Mannor S, Wehenkel L. The cross-entropy method for power system combinatorial optimisation problems. Paper presented at: 2007 IEEE Lausanne Power Tech; 2007; Lausanne, Switzerland.
32. Enacheanu B, Raison B, Caire R, Devaux O, Bienia W, HadjSaid N. Radial network reconfiguration using genetic algorithm based on the Matroid theory. *IEEE Trans Power Syst*. 2008;23(1):186-195.
33. Ahmadi H, Marti JR. Linear current flow equations with application to distribution systems reconfiguration. *IEEE Trans Power Syst*. 2015;30(4):2073-2080.

34. Su C-T, Chang C-F, Chiou J-P. Distribution network reconfiguration for loss reduction by ant colony search. *Electr Pow Syst Res.* 2005;75:190-199.
35. Ahmadi H. *Distribution Systems Analysis and Optimization* [PhD thesis]. Vancouver, Canada: The University of British Columbia; 2015.

How to cite this article: Sebaa K, Gelen A, Nouri H. Cross-entropy method for distribution power systems reconfiguration. *Engineering Reports.* 2019;1:e12052. <https://doi.org/10.1002/eng2.12052>